

# Annexure C

Appendix-XIII


## CERTIFICATE SAFE DRINKING WATER AND SANITARY CONDITION

Report No: -LAB/BLY/2024-25/ 1117

Dated: 09/ 04/ 2025

URN No: - TC141942500001117F

It is certified that an inspection team headed by **MR. NAVEEN SURI SAMPLING ASSISTANT (LABORATORY)** from, **UTTAR PRADESH JAL NIGAM (RURAL), BAREILLY** inspected the **BDM PUBLIC SCHOOL, NEAR LABHARI POLICE CHOWKI, MEERGANJ BAREILLY, UTTAR PRADESH** on **08/ 04/ 2025** (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

  
Assistant Engineer  
Signature with Seal: ..... Division Office .....  
U.P. Jal Nigam (Rural)  
Name : Ruman Singh  
Designation: Assistant Engineer

Assistant Engineer of  
The Govt. Public Health Department  
(PHED)/Authorized officer of the Local Body



Name & Address of the Office / Department:.....

To  
MANAGER

BDM PUBLIC SCHOOL,  
NEAR LABHARI POLICE CHOWKI, MEERGANJ BAREILLY.  
UTTAR PRADESH.


  
MANAGER  
BDM PUBLIC SCHOOL  
MEERGANJ, BAREILLY

  
Principal  
BDM Public School  
Meerganj, Bareilly


		<b>Analysis Report</b>				
		District Level Water Analysis Laboratory U.P. Jal Nigam (RURAL)				
Near M.B. Inter Collage, Gandhi Nagar, Bareilly (U.P.)						
URN No :- TC141942500001117F						
Customer Details						
Office Name and Address :		BDM PUBLIC SCHOOL, NEAR LABHARI POLICE CHOWKI MEERGANJ BAREILLY				
Ref Letter No & Date :		Nil.		DATE - 08.04.2025 Report No.- LAB/BLY/2024-25/1117		
Basic details of sample						
District	BAREILLY	Tehseel	MIRGANJ	Analysis Start Date	08.04.2025	
Village/AREA	MIRGANJ	Block	MIRGANJ			
Habitation	NEAR LABHARI POLICE CHOWKI, MEERGANJ	Location	BDM PUBLIC SCHOOL	Analysis Completion Date	09.04.2025	
Water Source	Submersible	Sample Code	PS- 1117			
Quantity of Sample	1 ltr	Date of Sample Collection	08.04.2025	Report Issue Date	09.04.2025	
Receiving Date	08.04.2025	Sample Collector (Lab)	VIPIN KUMAR	Sample Depositor	RAJAT KUMAR	
Environmental Condition						
Temperature		26°C		Humidity		
				51%		
Technical Data of Analysis						
S.No.	Analysis Parameter	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref.Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Colour	(CU)	0	5	15	IS 3025 (Part 4):2021
2	Odour	-	Agreeable	Agreeable	Agreeable	IS:3025(Part-5):2022
3	Taste	-	Agreeable	Agreeable	Agreeable	IS:3025(Part-5):2022
4	Turbidity	(NTU)	0.34	1.00	5.00	IS 3025 (Part 10) : 2022
5	TDS	(mg/L)	212	500	2000	IS 3025 (Part 16) : 2022
6	PH	-	7.45	6.5-8.5	6.5-8.5	IS 3025 (Part 11) :2022
7	Iron	(mg/L)	0.20	1.00	1.00	IS:3025(Part-53):2014
8	Sulphate	(mg/L)	16.1	200	400	IS 3025 (Part 24) : 2022
9	Alkalinity	(mg/L)	188	200	600	IS 3025 (Part 23) : 2019
10	Hardness	(mg/L)	170	200	600	IS 3025 (Part 21) : 2019
11	Chloride	(mg/L)	15	250	1000	IS 3025 (Part 32) : 2019
12	Calcium	(mg/L)	68	75	200	IS:3025(Part-40):2019
13	Magnesium	(mg/L)	24.78	30	100	APHA 23 Edition 3500Mg Method B
14	Fluoride	(mg/L)	0.015	1	1.5	IS:3025 (Part-60):2023
Note	1. This Certificate refers only to the particular sample(s) submitted for testing.					
	2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.					
	4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.					

Page no:-1/1


Email - anamika05anu@gmail.com  
U.P.J.N.BAREILLY (RURAL) Contact No:- 7318253236



  
**Prepared By**  
**अनिल कुमार**  
 मुख्यावस्था प्रबन्धक  
 जल विश्लेषण प्रयोगशाला  
 उ० प्र० जल निगम बरेली (ग्रामीण)

END OF THE REPORT

  
**Authorized signatory**  
 अनामिका सिंह  
 तकनीकी प्रबन्धक  
 जल विश्लेषण प्रयोगशाला  
 उ० प्र० जल निगम, बरेली (ग्रामीण)



  
**Principal**  
**B D M Public School**  
**Meerganj, Bareilly**

		<h2 style="text-align: center;">Analysis Report</h2>					
		<b>District Level Water Analysis Laboratory U.P.Jal Nigam (RURAL)</b>					
		<b>Near M.B.Inter Collage, Gandhi Nagar, Bareilly (U.P.)</b>					
<b>Customer Details</b>							
<b>Office Name and Address :</b>		BDM PUBLIC SCHOOL, NEAR LABHARI POLICE CHOWKI, MEERGANJ BAREILLY					
<b>Ref Letter No &amp; Date :</b>		Nil		DATE - 08.04.2025		Report No - LAB/BLY/2024-25/1117	
<b>Basic details of sample</b>							
District	BAREILLY	Tehseel	MIRGANJ	Analysis Start Date	08.04.2025		
Village/AREA	MIRGANJ	Block	MIRGANJ				
Habitation	NEAR LABHARI POLICE CHOWKI, MEERGANJ	Location	BDM PUBLIC SCHOOL	Analysis Completion Date	09.04.2025		
Water Source	Submersible	Sample Code	PS- 1117				
Quantity of Sample	1 ltr	Date of Sample Collection	08.04.2025	Report Issue Date	09.04.2025		
Receiving Date	08.04.2025	Sample Collector (Lab)	VIPIN KUMAR	Sample Depositor	RAJAT KUMAR		
<b>Environmental Condition</b>							
Temperature		26°C		Humidity		51%	
<b>Technical Data of Analysis</b>							
S.No.	Analysis Parameter	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref.Method of Analysis	
				Acceptable Limit	Permissible Limit		
1	2	3	4	5	6	7	
1	E-Coli	(CFU/100ml.)	0.00	No relaxation	No relaxation	APHA 23rd Edition : 2017,9222-B	
2	T-Coliform	(CFU/100ml.)	0.00	No relaxation	No relaxation	APHA 23rd Edition : 2017,9222-B	
<b>Note</b>							
1. This Certificate refers only to the particular sample(s) submitted for testing.							
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.							
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.							
4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.							

Page no:-1/1

END OF THE REPORT


Tested By


शिवानी

माइक्रो बायोलॉजिस्ट

जल विश्लेषण प्रयोगशाला

म०५० जल निगम, बरेली (प्राचीन)

  
**MANAGER**  
**BDM PUBLIC SCHOOL**  
**MEERGANJ, BAREILLY**

  
**Principal**  
**B D M Public School**  
**Meerganj, Bareilly**